



Engineering Cell
DELHI TECHNOLOGICAL UNIVERSITY

Shahbad Daultapur, Bawana Road, Delhi - 110042
Telephone: 011-27852188



F.No. DTU/Engg.Cell/002956/2021-22/Civil

Dated:

CORRIGENDUM - 01

Name of Work: Construction of Synthetic Athletic Track (400 mtr.) with 08 lane and warm up area at Sports Complex, DTU main Campus.

NIT No. : DTU/Engg.Cell/2022-23/06


Tender ID : 2023_DTU_236805_1

In reference to the tender ID mentioned above, the following changes/amendment have been taken in the NIT: -

| S.No. | Reference | As uploaded in NIT | As amended in NIT |
|-------|---|---|---|
| 1. | Page no. 5 & 7, Clause 3 & 1.2.1 respectively of NIT | Similar Work Means: Providing and Laying Synthetic Running Track and Allied Works | Similar Works Means: Providing and Laying 400 mtr. Synthetic Track and allied works duly certified by World Athletics/IAAF. |
| 2. | Page no. 5:- List of Documents required from bidder, S.No.10 of NIT | Nil | An undertaking on his letterhead to the effect that "I/We have not been blacklisted or debarred from any Govt. Department/Autonomous body/Public Sector Undertaking. In case, this information is found false/incorrect at any stage, DTU shall have absolute right to take any penal action against us including termination of the contract, blacklisting, forfeiture of EMD, Performance Guarantee, Security deposit etc." along with affidavit as per S.N |
| 3. | Page no. 19, Special Terms & Condition no. 43 of NIT | Nil | The phrase "Class 2 category" may be read as "Class 2" wherever it is written in the NIT. |
| 4. | Page no. 19, Special Terms & Condition no. 44 of NIT | Nil | Core cutting: - Thickness of synthetic track as laid at site shall be got checked from World Athletics approved laboratory by the contractor at his own cost and expenses in accordance with the procedure laid down in World Athletic Track and Field Facility manual - 2019 by taking out core from not less than 4 locations or as decided by the Engineer-in-charge. |
| 5. | Page no. 18, Special Terms & Condition no. 26 (g) of NIT | Nil | The Synthetic Track full PUR system "Polyurethane" must be free from Volatile Organic Compound. The contractor shall furnish a test report alongwith certificate issued by World Athletics clearly stating that the PUR system is free from VOC so payment shall be made against |



Engineering Cell
DELHI TECHNOLOGICAL UNIVERSITY
Shahbad Daulatpur, Bawana Road, Delhi - 110042
Telephone: 011-27852188





| | | | |
|------------------------------------|---|--|--|
| | | | Schedule of work, item no. 25 unless the contractor has furnished the said test report along with certificate. |
| 6. | Page no. 16, S.No. 21 of Special Terms & Condition | Synthetic Athletic Turf | Synthetic Athletic Track |
| 7. | Page 17, S.No. 23 (b) of Special Terms and Condition | For the purpose of testing of materials, two representative samples of size 1.25x1.25 metre (one stitched/glued and one un-stitched/un-glued) or as prescribed by World Athletics of Synthetic Athletic Track shall be taken from field. | For the purpose of testing of materials, two representative samples of size 0.30x0.30 meter (one stitched/glued and one un-stitched/un-glued) or as prescribed by World Athletics or as decided by the Engineer-in-Charge shall be taken from field. |
| 8. | All other terms and conditions will remain unchanged. | | |
| Inconvenience caused is regretted. | | | |

Further details of the tender can be seen at: <http://govtprocurement.delhi.goc.in>

Copy to:

1. Registrar, DTU.
2. COF, DTU
3. A.E. (Civil)/ J.E. (Civil) DTU
4. Guard File.


27/12/23
Chief Project Officer, DTU


27/02/2023
A.E. (Civil), DTU